

Reliability Analysis of blowers of a Wastewater Treatment Plant

Zubaida Al Abdali*, **Sheika Al Alwai***, **Aiysha Al Hosni***,
Marwa Al Sinani*, **Padmavathi N****

*Dept. of Chemical Engineering, National University of Science and Technology, Oman.

**Department of Applied Mathematics & Science, National University of Science and Technology, Oman.

Abstract

Blowers of a wastewater treatment plant are analyzed. Real down time data of the two blowers on failures, repairs, and cost incurred in carrying out the maintenance activities, are collected from the plant. Blowers are used to treat the waste and sewage water and convert the same to useful water, which is then used for watering the plants. The high-pressure air is blown through the blowers into the sewage treatment tank, which increases the sewage and air space and removes nitrogen and ammonia from the sewage. The data are summarized using Easy-Fit software for the important descriptive outcomes of the plant. Reliability measures for the system effectiveness are also obtained for both the blowers and compared. Semi- Markov and regenerative processes have been used for analysis.

Keywords: Reliability, Blowers, Wastewater plant, failures, repairs, Semi – Markov, regenerative processes

I. NOMENCLATURE

s_0	Operative state of the blower
s_1	Unit fails due to repairable failure
s_2	Unit fails due to replaceable failure
s_3	Unit fails due serviceable failure
λ_1	Rate of failure of any component of the blower 211
α_1	Repair rate for repairable failures for the blower 211
β_1	Repair rate for replaceable failures for the blower 211

γ_1	Repair rate for serviceable failures for the blower 211
λ_2	Rate of failure of any component of the blower 411
α_2	Repair rate for repairable failures for the blower 411
β_2	Repair rate for replaceable failures for the blower 411
γ_2	Repair rate for serviceable failures for the blower 411
p_1	Probability of occurrence of repairable failures for the blower 211
p_2	Probability of occurrence of replaceable failures for the blower 211
p_3	Probability of occurrence of serviceable failures for the blower 211
q_1	Probability of occurrence of repairable failures for the blower 411
q_2	Probability of occurrence of replaceable failures for the blower 411
q_3	Probability of occurrence of serviceable failures for the blower 411
\odot	Symbol for Laplace Convolution
\otimes	Symbol for Stieltje's convolution
*	Symbol for Laplace Transforms
**	Symbol for Laplace Stieltje's transforms
A_0	Steady state availability of the system
$\phi_{ij}(t)$	c.d.f. of first passage time from a regenerative state i to a failed state j
$p_{ij}(t), Q_{ij}(t)$	p.d.f. and c.d.f. of first passage time from a regenerative state I to the regenerative state j or to a failed state j in $(0, t]$.
$g_1(t), G_1(t)$	p.d.f. and c.d.f. of repair rate for repairable failures for the blower 211
$g_2(t), G_2(t)$	p.d.f. and c.d.f. of repair rate for replaceable failures for the blower 211
$g_3(t), G_3(t)$	p.d.f. and c.d.f. of repair rate for serviceable failures for the blower 211
$h_1(t), H_1(t)$	p.d.f. and c.d.f. of repair rate for repairable failures for the blower 411
$h_2(t), H_2(t)$	p.d.f. and c.d.f. of repair rate for replaceable failures for the blower 411
$h_3(t), H_3(t)$	p.d.f. and c.d.f. of repair rate for serviceable failures for the blower 411

*p.d.f.: probability density function

c.d.f.: cumulative distribution function

II. INTRODUCTION

Various industrial systems were analysed in the past under different operating conditions. Various researchers in the past have analysed different industrial systems under different operating conditions and assumptions in understanding the system behaviour in terms of reliability indices and cost benefit analysis. Goel et.al. [1] worked on system analysis with correlated failures and repairs. Systems with assumptions of regular repairmen, tiredness of repairmen, and partial or complete failure units, for analysis was considered by Tuteja et.al. [2]-[5]. Later Rizwan et. al. [6]-[10] extended the previous study and analysed the system for different operating conditions of comparative analysis, rest period of repairman, systems with accident and inspection, hot standby systems. Taneja et. al. [11] worked on a two-unit PLC system with four failures. Rizwan et. al. [12]-[13] dealt with secondary coating line manufacturing machine and a two-unit system with partial failure mode. Rizwan [14]-[17] shown the modeling strategies / applications to an industrial system and system analysis with two repairmen. Zuhair and Rizwan [18] shown an analysis of a two-unit system. Rizwan et. al. [19]-[22] presented studies on programmable logic controllers and continuous casting plant. Mathew et. al. [23]-[31] further studied continuous casting plant with different case studies and variations. Rizwan et. al. [32]-[34] analysed a hot standby system and a desalination plant system and obtained reliability indices of interest. Saud et.al [35]-[36] considered a centrifugal pump of refinery system for analysis. Al-Amri et. al. [37] analysed recycle gas compressor; Al Maqbali et.al. [38] analysed AC compressors; Al-Balushi et.al. [39] analysed a sewage lifting centrifugal pump. Mathew and Rizwan [40] carried out a simple maintenance analysis of port cranes data. Padmavathi et.al. [41]-[46] extensively studied a desalination plant with seven evaporators and obtained various reliability indices along with the cost-benefit analysis of the system. Rizwan et.al. [47]-[49] again considered the desalination plant and variations under different operating conditions of the plant with shutdown during winter season and repair / maintenance on FCFS basis, and inspections were studied. Sharma and Kaur [50]-[51] studied the standby systems with three failure categories and the compressor systems with and without provision of priority to failed compressor unit. Rizwan et.al. [52]-[56] estimated the relevant reliability indices of the different case specific situations of the wastewater treatment plant and anaerobic batch reactor treating fruits and vegetables waste. Rizwan & Mathew [56] carried out the port cranes analysis under minor and major categories of electrical and mechanical components failures of cranes. Later, Al-Rahbi et.al. [57]-[65] focused on the rodding anode plant in aluminium industry where different plant situations are explored for subsystems and main system under multiple repairmen and multiple unit's maintenance management strategies. Much has been discussed by Taj et.al. [66]-[76] about a cable plant sub-systems and the main system as single machine, different failure types, with storage of surplus produce, winter operating strategy, comparative study between the models, and a review mentioning about the future scope of using new distributions and fuzzy optimization models. Recently, Rizwan and Taj [77] analysed a PLCs controlled port system and obtained the reliability indices of interest reflecting the system effectiveness.

The main focus of the entire literature is to analyse the complex industrial systems from reliability perspective and obtain the relevant indices reflecting the system behaviour. One such plant in Oman has been identified and analysed as a potential case study to understand the operational capabilities of the plant by obtaining reliability indicators. For the purpose of analysis, 8 years of maintenance data of the two blowers have been collected from the plant. Failure and repair rates obtained therein have been estimated from the data for further analysis.

In wastewater treatment, the blowers ensure the supply of oxygen needed when high-pressure air is blown into the sewage treatment tank, which increases the sewage and air space and removes nitrogen and ammonia from the sewage. Moreover, complex microbes in activated sludge and organic nutrients in wastewater forms a complex food chain. The first to carry out the disinfection task are the oxygen-producing bacteria and spongy fungi. Bacteria, especially spherical bacteria, play the most important role. The role of air blower is to provide oxygen to the bacteria. The air blower works by pumping air to them. The air contains oxygen, so that they can survive and provide better conditions for survival.

In the wastewater treatment plant identified, two types of blowers AR: BLW-411 and AR: BLW-211 are used to treat the waste and sewage water and convert the same to useful water which can be used for plants. AR: BLW-411 is a Positive Displacement Blower, and it supplies the air to Pre-Aeration tanks 1 and 2 to remove ammonia from the sewage water to the great Chambers 1 and 2. Moreover, this blower supplies air to Sludge storage 1 and 2 to allow the bacteria to grow and to separate the sludge from the sewage water. AR: BLW-211 is a Centrifugal Blower used at Biological Treatment Area where the air is pumped into the sludge seeds to allow bacteria to grow through the sludge seeds and later the bacteria will be removed by pumping air. Also, it's used to supply air to Aeration tanks and membranes.

Mainly, two types of maintenance, Corrective and Preventive maintenance are carried out on the blowers. Corrective maintenance is performed whenever there is a leakage or a repair with the components of the blowers. It is a series of operations that are performed to repair and to calibrate the blowers according to a set time plan. Preventive maintenance operations are carried out daily, weekly, monthly and yearly which includes the periodic inspection of the different components of the blowers, cleaning, lubricating, oiling and changing some of the minor components if necessary to extend the useful lifetime of the blowers.

Both the blowers are analyzed probabilistically using semi-Markov processes and regenerative point techniques. The mean times to system failure and the unit availability are estimated numerically for both the blowers and compared.

III. SUMMARISATION OF THE DATA

Estimated Rates for Blower 211:

Estimated rate of failure of any component of the blower 211(λ_1) = 0.0000138 per hour

Estimated repair rate for repairable failures for the blower 211(α_1) = 0.007546 per hour

Estimated repair rate for replaceable failures for the blower 211(β_1) = 0.002364 per hour

Estimated repair rate for serviceable failures for the blower 211(γ_1) = 0.00497 per hour

Probability of occurrence of repairable failures for the blower 211 (p_1) = 0.13636

Probability of occurrence of replaceable failures for the blower 211 (p_2) = 0.12121

Probability of occurrence of serviceable failures for the blower 211 (p_3) = 0.74242

Estimated Rates for Blower 411:

Estimated rate of failure of any component of the blower 411 (λ_2) = 0.0000169 per hour

Estimated repair rate for repairable failures for the blower 411(α_2) = 0.02551 per hour

Estimated repair rate for replaceable failures for the blower 411(β_2) = 0.05303 per hour

Estimated repair rate for serviceable failures for the blower 411(γ_2) = 0.00503 per hour

Probability of occurrence of repairable failures for the blower 411 (q_1) = 0.15152

Probability of occurrence of replaceable failures for the blower 411 (q_2) = 0.21212

Probability of occurrence of serviceable failures for the blower 411 (q_3) = 0.63636

IV. STATE TRANSITION TABLE

The description of the states for both the blowers is depicted by the state transition table (Table 1):

Table 1: State Transition Table

S_i	S_0	S_1	S_2	S_3
S_0	0	$P\lambda$	$Q\lambda$	$R\lambda$
S_1	α	0	0	0
S_2	β	0	0	0
S_3	γ	0	0	0

For Blower 211, $\lambda = \lambda_1, \alpha = \alpha_1, \beta = \beta_1, \gamma = \gamma_1, P = p_1, Q = p_2, R = p_3$

For Blower 411, $\lambda = \lambda_2, \alpha = \alpha_2, \beta = \beta_2, \gamma = \gamma_2, P = q_1, Q = q_2, R = q_3$

V. TRANSITION PROBABILITIES AND MEAN SOJOURN TIMES

A state transition table showing the possible states of transition of the blowers is shown in Table 1. The epochs of entry into states 2, 3, and 4 are regeneration points. The transition probabilities are given by,

$$\begin{aligned} dQ_{01} &= p_1 e^{-\lambda t} dt, \quad dQ_{02} = p_2 e^{-\lambda t} dt, \\ dQ_{03} &= p_3 e^{-\lambda t} dt, \quad dQ_{10} = \alpha e^{-\alpha t} dt, \\ dQ_{20} &= \beta e^{-\beta t} dt, \quad dQ_{30} = \gamma e^{-\gamma t} dt \end{aligned} \quad (1-6)$$

For Blower 211, $\lambda = \lambda_1, \alpha = \alpha_1, \beta = \beta_1, \gamma = \gamma_1$

For Blower 411, $\lambda = \lambda_2, \alpha = \alpha_2, \beta = \beta_2, \gamma = \gamma_2$

The transition probabilities p_{ij} are given below:

$$\begin{aligned} p_{01} + p_{02} + p_{03} &= 1 \\ p_{10} = p_{20} = p_{30} &= 1 \end{aligned} \quad (7-10)$$

The mean sojourn time, μ_i in the regenerative state 'i' is defined as the time of stay in that state before transition to any other state. If T denotes the sojourn time in the regenerative state 'i', then:

$$\mu_i = E(T) = P(T > t); \quad \mu_0 = \int_0^{\infty} e^{-\lambda t} dt = \frac{1}{\lambda} \quad (8)$$

The unconditional mean time taken by the system to transit, for any regenerative state 'j' when it (time) is counted from the epoch of entry into state 'i' is mathematically stated as:

$$m_{ij} = \int_0^{\infty} t dQ_{ij}(t) = -q_{ij}'(0), \quad \sum_j m_{ij} = \mu_i$$

VI. THE MATHEMATICAL ANALYSIS

A. Mean time to system failure

Regarding the failed states as absorbing states and applying the arguments used for regenerative processes, the following recursive relation for $\phi_i(t)$ is obtained:

$$\phi_0(t) = Q_{01}(t) + Q_{02}(t) + Q_{03}(t) \quad (9)$$

Now the mean time to system failure (MTSF) when the unit started at the beginning of state 0, is

$$MTSF = \lim_{s \rightarrow 0} \frac{1 - \phi_0^*(s)}{s} = \frac{1}{\lambda} \quad (10)$$

For Blower 211, $\lambda = \lambda_1$

For Blower 411, $\lambda = \lambda_2$

B. Availability Analysis of the Unit of the Plant

Using the probabilistic arguments and defining $A_i(t)$ as the probability of unit entering into upstate at the instant t , given that the unit entered in regenerative state i at $t=0$, the following recursive relations are obtained for $A_i(t)$:

$$A_0(t) = M_0(t) + q_{01}(t) \odot A_1(t) + q_{02}(t) \odot A_2(t) + q_{03}(t) \odot A_3(t),$$

$$A_1(t) = q_{10}(t) \odot A_0(t),$$

$$A_2(t) = q_{20}(t) \odot A_0(t)$$

$$A_3(t) = q_{30}(t) \odot A_0(t)$$

$$\text{Where } M_0(t) = e^{-\lambda t}, \quad (11-14)$$

Taking Laplace Transforms of the above equations and solving them for $A_0^*(s)$, using the determinants method the following is obtained:

$$N_1(s) = \begin{vmatrix} M_0^*(s) & -q_{01}^*(s) & -q_{02}^*(s) & -q_{03}^*(s) \\ 0 & 1 & 0 & 0 \\ 0 & 0 & 1 & 0 \\ 0 & 0 & 0 & 1 \end{vmatrix}$$

$$D_1(s) = \begin{vmatrix} 1 & -q_{01}^*(s) & -q_{02}^*(s) & -q_{03}^*(s) \\ -q_{10}^*(s) & 1 & 0 & 0 \\ -q_{20}^*(s) & 0 & 1 & 0 \\ -q_{30}^*(s) & 0 & 0 & 1 \end{vmatrix}$$

$$A_0 = \lim_{s \rightarrow 0} s A_0^*(s) = \frac{N_1(0)}{D_1'(0)} = \frac{\frac{1}{\lambda}}{\frac{1}{\lambda} + \frac{1}{\alpha} + \frac{1}{\beta} + \frac{1}{\gamma}} \quad (15)$$

For Blower 211, $\lambda = \lambda_1, \alpha = \alpha_1, \beta = \beta_1, \gamma = \gamma_1$

For Blower 411, $\lambda = \lambda_2, \alpha = \alpha_2, \beta = \beta_2, \gamma = \gamma_2$

Using the data as summarized in Section III and various expressions for reliability indicators obtained therein in sections IV & V, the following values of unit effectiveness are estimated:

Mean Time to Failure for the blower 211=72,267 hours

Availability (A_0) for the blower 211 = 0.9896

Mean Time to Failure for the blower 411 = 59098 hours

Availability (A_0) for the blower 411 = 0.9957

VI. DESCRIPTIVE STATISTICS USING EASY- FIT SOFTWARE FOR THE BLOWERS 211 & 411

Table 2: Descriptive Statistics for failure times of Blower 211

Descriptive Statistics	
Statistic	Value
Sample Size	66
Range	86760
Mean	72267.0
Variance	5.6995E+8
Std. Deviation	23874.0
Coef. of Var.	0.33035
Std. Error	2938.6
Skewness	-0.57228
Kurtosis	-0.76713
Percentile	Value
Min	17520
5%	26526.0
10%	36480
25% (Q1)	54720
50% (Median)	76200
75% (Q3)	93360
90%	99168.0
95%	1.0259E+5
Max	1.0428E+5

Table 3: Descriptive Statistics for failure times of Blower 411

Descriptive Statistics	
Statistic	Value
Sample Size	33
Range	74400
Mean	59098.0
Variance	6.1425E+8
Std. Deviation	24784.0
Coef. of Var.	0.41937
Std. Error	4314.3
Skewness	0.13717
Kurtosis	-1.3119
Percentile	Value
Min	26280
5%	26280
10%	27144.0
25% (Q1)	33120
50% (Median)	62040
75% (Q3)	78060
90%	96168.0
95%	98664.0
Max	1.0068E+5

VII. CONCLUSION

Easy-fit outcomes as obtained in Tables 2 & 3 reveals that the average time to failure for the Blower 211 is 72,267 hours and for the blower 411 is 59098 hours. The expected time for which the Blower 211 is in operation before it completely fails is more than the blower 411 which is also shown in Section VI. Further to this, the coefficient of variation for failure time is less for blower 211 compared to blower 411. The analytical results obtained in section VI B shows that the availability index for blower 411 is slightly better than the blower 211.

Therefore, good maintenance practices and scheduled inspections need to be reviewed in order to improve the operational capabilities of the blower 411 when compared to Blower 211.

REFERENCES

- [1] Goel L., Shrivastava, P. and Gupta, R. (1992). A two-unit cold standby system with correlated failures and repairs, International Journal of Systems Science. 23(3), pp. 379-391,
- [2] Taneja, G. Rizwan, S. M. and Rajeev, K. (1992). Profit Analysis of a system with perfect repair at partial failure and priority for repair to complete failed unit" Journal of Pure and applied Mathematika Sciences, Vol. 35, No. 1-2, pp. 131-141.
- [3] Tuteja, R., Rizwan, S. M. and Taneja, G. (1999). A two-server system with regular repairman, who is not always available. In: 3rd Annual Conference of ISITA and National Symposium on Management Science and Statistics – Applications to Trade & Industry. Amritsar, Punjab, India: pp.231-237.
- [4] Tuteja, R., Rizwan, S. M. and Taneja, G. (2000). Profit evaluation of a two-unit cold standby system with tiredness and two types of repairmen. Journal of Indian Society of Statistics and Operation Research, 21(1-4), pp.1-10.
- [5] Tuteja, R., Rizwan, S. M. and Taneja, G. (2000). Profit analysis of a system with perfect repair at partial or complete failure, Pure and Applied Mathematika Sciences, 52, (2), pp. 7-14.
- [6] Rizwan, S. M., Garima., and Mohiuddin, A. (2005). Maintenance Analysis of PLCs, Regional Conference on Maintenance Management, Caledonian College of Engineering, Sultanate of Oman, 2nd October 2005, pp 265-270.
- [7] Rizwan, S. M., Ramachandran, K.P. and Mohiuddin, A. (2005). Reliability of a Technological System with Rest Period of Repairman, Caledonian Journal of Engineering, 1(4), pp.1-4.
- [8] Rizwan, S. M., Chauhan, H. and Taneja, G. (2005). Stochastic analysis of systems with accident and inspection. Emirates Journal of Engineering Research, 10(2), pp.81-87.

- [9] Rizwan, S. M., Khurana, V., and Taneja, G. (2005). Reliability modeling of a hot standby PLC system. International Conference on Communication, Computer and Power. Muscat, Sultanate of Oman: pp.486-489.
- [10] Rizwan, S. M., and Ramachandran, K. (2006). Maintenance Management Strategies" International Workshop on Successful Strategies in Supply Chain Management, The Hong Kong Polytechnic University, Hong Kong, 5-6 January 2006, pp 255-260.
- [11] Taneja, G., Vipin, K., and Rizwan, S. M. (2006). Economic Analysis of a Reliability model for two-unit Programmable Logic Controller cold standby System with four types of Failure, Journal of Pure and Applied Mathematika Sciences, Vol. LXIII, No. 1-2, pp. 65- 77.
- [12] Rizwan, S. M., Mathew, A., Majumdar., and Ramachandran, K. (2006). Maintenance Analysis of a Secondary Coating Line Manufacturing Machine, National Conference on Recent Developments and Future Trends in Mechanical Engineering, National Institute of Tech., HP, India, 3-4 Nov 2006, pp 251-257.
- [13] Rizwan, S. M., Ramanathan, S. and Mohiuddin, A. (2006). MTSF Analysis of a Two Unit System with Partial Failure Mode. Caledonian Journal of Engineering, 1(2), pp.1-4.
- [14] Rizwan, S. M. (2006). Reliability Modeling Strategy of an Industrial System. ISBN: 0-7699-2569-9, in Proceedings of IEEE Conference Publications of Computer Society, First International Conference on Availability, Reliability and Security (ARES'06), Vienna University of Technology, Austria, 20-22 April 2006. DOI: 10.1109/ARES.2006, pp 625-630.
- [15] Rizwan, S. M. (2007). Reliability analysis of a two-unit system with two repairmen. Caledonian Journal of Engineering, 3(2), pp.1-5.
- [16] Rizwan, S. M. (2007). An Industrial Application of Reliability Modeling, International Conference QRM Quality Reliability and Maintenance, University of Oxford, UK, 22 – 23 March 2007, pp 247-253.
- [17] Rizwan, S. M. (2007). Reliability analysis of a two-unit system with two repairmen. Caledonian Journal of Engineering, 3(2), pp.1-5.
- [18] Zuhair, Al Hemyari. and Rizwan, S. M. (2007). Reliability Analysis of a Two Unit System, in proceedings of IEEE Conference Publications, IEEE International Conference on Industrial Engineering and Engineering Management, Singapore, 2-5 December 2007, ISBN: 978-1-4244-1529-8DOI:10.1109/IEEM.2007.4419395, pp 1265-1268.
- [19] Rizwan, S. M., Khurana, V. and Taneja, G. (2007). Modeling and optimization of a single-unit PLC system. International Journal of Modeling and Simulation, 27(4), pp.361-368.
- [20] Rizwan, S. M., Khurana, V., Taneja, G., and Mohiuddin, A. (2008). Reliability

Analysis of a single unit PLC with inspection, i - manager's Journal on Future Engineering and Technology, vol.3, No. 4, pp. 19-26.

- [21] Rizwan, S. M., Mathew, A., Majumder. M, and Ramachandran. K. (2008) Reliability and Availability of a Continuous Casting Plant" in proceedings of IEEE Conference Publications, IEEE International Conference on Industrial Engineering and Engineering Management, Singapore, 8-11 Dec. 2008, DOI: 10.1109/IEEM.2008.4737927, pp. 541-544.
- [22] Rizwan, S. M., Mathew, A., and Taneja, G. (2009). Reliability Analysis of a Continuous Casting Plant" i - manager's Journal on Future Engineering and Technology, vol.5, No. 1, pp 15-21.
- [23] Mathew, A., Rizwan, S. M., Majumder, M. and Ramachandran, K. (2009). MTSF and availability of a two-unit CC plant. In: 3rd International Conference on Modeling, Simulation, and Applied Optimization. Sharjah, UAE: pp.1-5.
- [24] Mathew, A., Rizwan, S. M., Majumder, M., Ramachandran, K. and Taneja, G. (2009). Optimization of a single unit CC plant with scheduled maintenance policy. In: 2nd International Conference on Recent Advances in Material Processing Technology. Kovilpatti, TN, India: SME, pp.609-613.
- [25] Mathew, A., Rizwan, S. M., Majumder, M., Ramachandran, K. and Taneja, G. (2009). Profit evaluation of a single unit CC plant with scheduled maintenance. Caledonian Journal of Engineering, 5(1), pp.25-33.
- [26] Mathew, A., Rizwan, S. M., Majumder, M., Ramachandran, K. and Taneja, G. (2010a). Comparative analysis between profits of the two models of a CC plant. In: International Conference on Modeling, Optimization, and Computing. Durgapur, West Bengal, India: AIP, 1298(1), pp.226-231.
- [27] Mathew, A., Rizwan, S. M., Majumder, M., Ramachandran, K. and Taneja, G. (2010b). Reliability modeling and analysis of a two-unit parallel CC plant with different installed capacities. Journal of Manufacturing Engineering, 5(3), pp.197-204.
- [28] Mathew, A., Rizwan, S. M. & Gulshan, T. (2010). Comparative Analysis between the Two Models of a CC Plant' International Conference on Mathematics and Soft Computing, Panipat, Haryana, India, 4-5 Dec. 2010, pp. 132-135.
- [29] Mathew, A., Rizwan, S. M., Majumder, M. and Ramachandran, K. (2011). Reliability modelling and analysis of a two-unit continuous casting plant. Journal of the Franklin Institute, 348(7), pp.1488-1505.
- [30] Mathew, A., Rizwan, S. M., Majumder, M., Ramachandran, K. and Taneja, G. (2011). Reliability analysis of an identical two-unit parallel CC plant system operative with full installed capacity. International Journal of Performability Engineering, 7(2), pp.179-185.

- [31] Mathew, A., Rizwan, S. M., Majumder, M. & Ramachandran, K. (2011). Reliability modeling and analysis of a two-unit continuous casting plant. *Journal of the Franklin Institute*, 348, doi: 10.1016/j.jfranklin.2010.04.016, pp. 1488-1505.
- [32] Rizwan, S. M., Padmavathi, N., and Taneja, G. (2010). Cost benefit Analysis of a desalination Unit, International Conference on Mathematics and Soft Computing, Panipat, Haryana, India, 4-5 Dec. 2010, pp. 139-142.
- [33] Rizwan, S. M., Khurana, V. and Taneja, G. (2010). Reliability analysis of a hot standby industrial system. *International Journal of Modeling and Simulation*, 30(3), pp.315-322.
- [34] Rizwan, S. M., Padmavathi, N., Taneja, G., Mathew, A., and Ali Mohammed Al-Balushi. (2010) Probabilistic Analysis of a Desalination Unit with Nine Failure Categories, World Congress on Engineering 2010, IAENG International Conference of Applied Mathematics, Imperial College London, UK, 30 June -2 July 2010, pp. 1877-1880.
- [35] Saud, Talib., Mathew, A., & Rizwan, S. M. (2011). Reliability and Availability Assessment of a Centrifugal Pump. International Conference on Harnessing Technology, Crown Plaza, Sultanate of Oman, 13-14 Feb. 2011, pp. 34.
- [36] Saud, Talib Al Amri., Mathew, A., and Rizwan, S. M. (2011). Reliability Modeling and Analysis of a Refinery Based Centrifugal Pump. *Caledonian Journal of Engineering*, Vol. 07, No. 01, pp. 38-42.
- [37] Al-Amri, M., Mathew, A., and Rizwan, S. M. (2011). A Probabilistic Analysis of Recycle Gas Compressor', National Symposium on Engineering Final Year Projects, College of Engineering and Architecture, University of Nizwa, Sultanate of Oman.
- [38] Al-Maqbali, M., Mathew, A., and Rizwan, S. M. (2012). A Probabilistic Risk Analysis of an A.C. Air Compressor (heavy duty)' in Proc. 2nd NSEFYP, 2nd National Symposium on Engineering Final Year Projects, University of Nizwa, Sultanate of Oman.
- [39] Al - Balushi, M., Mathew, A., and Rizwan, S. M. (2012). Probabilistic Analysis of a Sewage Lifting Centrifugal Pump (Case Study)' in Proc. 2nd NSEFYP, 2nd National Symposium on Engineering Final Year Projects, 15th May 2012, University of Nizwa, Sultanate of Oman.
- [40] Mathew, A. and Rizwan, S. M. (2012). Maintenance Analysis of Port PLCs – Case Study, *Caledonian Journal of Engineering*, 8(2), pp. 52-57.
- [41] Padmavathi, N., Rizwan, S. M., Pal, A. and Taneja, G. (2012). Reliability analysis of an evaporator of a desalination plant with online repair and emergency shutdowns. *Aryabhatta Journal of Mathematics & Informatics*, 4(1), pp.1-12.

- [42] Padmavathi, N., Rizwan, S. M., Pal, A. and Taneja, G. (2013). Comparative analysis of the two models of an evaporator of a desalination plant. International Conference on Information and Mathematical Sciences. Bathinda, Punjab, India: pp.418-422.
- [43] Padmavathi, N., Rizwan, S. M., Pal, A. and Taneja, G. (2013). Probabilistic analysis of an evaporator of a desalination plant with priority for repair over maintenance. International Journal of Scientific and Statistical Computing, 4(1), pp.1-8.
- [44] Padmavathi, N., Rizwan, S. M., Pal, A. and Taneja, G. (2014). Probabilistic analysis of a desalination plant with major and minor failures and shutdown during winter season. International Journal of Scientific and Statistical Computing, 5(1), pp.15-23.
- [45] Padmavathi, N., Rizwan, S. M., Pal, A. and Taneja, G. (2014). Probabilistic analysis of a seven-unit desalination plant with minor/major failures and priority given to repair over maintenance. Aryabhata Journal of Mathematics & Informatics, 6(1), pp.219-230.
- [46] Padmavathi, N., Rizwan, S. M. and Senguttuvan, A. (2015). Comparative analysis between the reliability models portraying two operating conditions of a desalination plant. International Journal of Core Engineering and Management, 1(12), pp.1-10.
- [47] Rizwan, S. M., Padmavathi, N., Anita, Pal. and Taneja, G. (2013). Reliability Analysis of a Seven Unit Desalination Plant with Shutdown During Winter Season and Repair / Maintenance on FCFS Basis. International Journal of Performability Engineering, Vol. 9, No. 5, Sep 2013, pp. 523-528.
- [48] Rizwan, S. M., Padmavathi, N., Anita Pal, Taneja, G. (2013). Probabilistic Analysis of an Evaporator of a Desalination Plant with Inspection. i-manager's Journal on Mathematics, Vol. 2, No. 1, pp. 27-34.
- [49] Padmavathi, N., Rizwan S. M. and Taneja, G. (2015). Performance analysis of a desalination plant as a single unit with mandatory shutdown during winter. Arya Bhatta Journal of Mathematics and Informatics, Vol. 7, No.1, pp. 195-202.
- [50] Sharma, U. and kaur, J. (2014). Availability Analysis of a Standby System with Three Types of Failure Categories. IOSR Journal of Mathematics, 10(2), pp.23-28.
- [51] Sharma, U. and kaur, J. (2014). Comparative Study of Standby Compressor Systems with and without Provision of Priority to Failed Compressor Unit, International Journal of Applied Mathematics & Statistical Sciences,3(6), pp.1-8.
- [52] Rizwan. S. M., Thanikal, J. and Torijos, M. (2013). Reliability Analysis of a Domestic Wastewater Treatment Plant' in Proc. of International Conference on Harnessing Technology, 2-3 Dec 2013, Sultanate of Oman.

- [53] Rizwan, S. M. and Thanikal, J. (2014). Reliability analysis of a wastewater treatment plant with inspection. *i-manager's Journal on Mathematics*, 3(2), pp.21-26.
- [54] Rizwan, S. M., Thanikal, J. and Torrijos, M. (2014). A general model for reliability analysis of a domestic wastewater treatment plant. *International Journal of Condition Monitoring and Diagnostic Engineering Management*, 17(3), pp.3-6.
- [55] Rizwan, S. M., Thanikal, J., Padmavathi, N. & Yazdi, H. (2015). Reliability & Availability Analysis of an Anaerobic Batch Reactor Treating Fruit and Vegetable Waste. *International Journal of Applied Engineering Research*, Vol. 10, Issue 24, pp. 44075-44079.
- [56] Rizwan, S. M. and Mathew, A. (2015). Performance analysis of port cranes. *International Journal of Core Engineering and Management*, 2(1), pp.133-140.
- [57] Al Rahbi, Y., Rizwan, S. M., Alkali, B., Cowell, A. and Taneja, G. (2017). Reliability analysis of a subsystem in aluminum industry plant. In: 6th International Conference on Reliability, Infocom Technologies and Optimization (Trends and Future Directions), Noida, UP, India, pp.199-203.
- [58] Al Rahbi, Y., Rizwan, S. M., Alkali, B., Cowell, A. and Taneja, G. (2017). Reliability analysis of rodding anode plant in aluminum industry. *International Journal of Applied Engineering Research*, 12(16), 2017b, pp.5616-5623.
- [59] Al Rahbi, Y., Rizwan, S. M., Babakalli, Alkali., Andrew, Cowel. and Gulshan Taneja. (2017). Reliability Analysis of a Subsystem in Aluminum Plant, in Proc. of 6th International Conference on Reliability, Infocom Technologies and Optimization, IEEE Conference, Amity Institute of Information Technology, Amity University, Noida, UP, India. 20-22 Sep. 2017, pp. 203-207,.
- [60] Al Rahbi, Y., Rizwan, S. M., Alkali, B., Cowell, A. and Taneja, G. (2018). Maintenance analysis of a butt thimble removal station in aluminum plant. *International Journal of Mechanical Engineering and Technology*, 9(4), pp. 695-703.
- [61] Al Rahbi, Y., Rizwan, S. M., Alkali, B., Cowell, A. and Taneja, G. (2018). Reliability analysis of rodding anode plant in an aluminum industry with multiple repairmen. *Advances and Applications in Statistics*, 53(5), pp.569-597.
- [62] Al Rahbi, Y., Rizwan, S. M., Alkali, B., Cowell, A. and Taneja, G. (2019). Reliability analysis of a rodding anode plant in aluminum industry with multiple units' failure and single repairman. *International Journal of System Assurance Engineering and Management*, 10(1), pp.97-109.
- [63] Al Rahbi, Y., Rizwan, S. M., Alkali, B., Cowell, A. and Taneja, G. (2019). Reliability analysis of multiple units with multiple repairmen of rodding anode plant in aluminum industry. *Advances and Applications in Statistics*, 54(1),

pp.151-178.

- [64] Al Rahbi, Y., and Rizwan, S. M. (2020). A Comparative Analysis between the Models of a Single Component with Single Repairman & Multiple Repairmen of an Aluminium Industry, International Conference on Computational Performance Evaluation, North-Eastern Hill University, Shillong, Meghalaya, India. Jul 2-4.
- [65] Al Rahbi, Y., Rizwan, S. M. (2020). A Comparative Analysis between the models of a Single Component with single repairman & multiple repairmen of an Aluminum Industry, International Conference on Computational Performance Evaluation, IEEE Conference, 2-4 July 2020, Department of Biomedical Engineering, North-Eastern Hill University, Shillong, Meghalaya, India, IEEE Proceedings, pp. 132-135.
- [66] Taj, S., Rizwan, S. M., Alkali, B., Harrison, D. and Taneja, G. (2017a). Probabilistic modelling and analysis of a cable plant subsystem with priority to repair over preventive maintenance, *i-manager's Journal on Mathematics*, 6(3), pp.12-21.
- [67] Taj, S., Rizwan, S. M., Alkali, B., Harrison, D. and Taneja, G. (2017). Reliability analysis of a single machine subsystem of a cable plant with six maintenance categories. *International Journal of Applied Engineering Research*, 1(8), pp. 1752-1757.
- [68] Taj, S., Rizwan, S. M., Alkali, B., Harrison, D. and Taneja, G. (2017). Reliability modeling and analysis of a single machine subsystem of a cable plant. In proceedings of 7th International Conference on Modeling, Simulation, and Applied Optimization. Sharjah, UAE: IEEE, pp.1-4.
- [69] Taj, S., Rizwan, S. M., Alkali, B., Harrison, D. and Taneja, G. (2018). Comparative analysis of reliability models of a cable plant portraying summer and winter operating strategy. In: 9th International Conference on Quality, Reliability, Infocom Technology and Business Operations. Delhi, India: Springer.
- [70] Taj, S., Rizwan, S. M., Alkali, B., Harrison, D. and Taneja, G. (2018). Performance analysis of a rod breakdown system. *International Journal of Engineering and Technology*, 7(3.4), pp.243-248.
- [71] Taj, S., Rizwan, S. M., Alkali, B., Harrison, D. and Taneja, G. (2018). Performance and cost benefit analysis of a cable plant with storage of surplus produce. *International Journal of Mechanical Engineering and Technology*, 9(8), pp.814-826.
- [72] Taj, S., Rizwan, S. M., Alkali, B., Harrison, D. and Taneja, G. (2018). Profit analysis of a cable manufacturing plant portraying the winter operating strategy. *International Journal of Mechanical Engineering and Technology*, 9(11), pp.370-381.
- [73] Taj, S., Rizwan, S. M., Alkali, B., Harrison, D. and Taneja, G. (2018).

Reliability analysis of a 3-unit subsystem of a cable plant. *Advances and Applications in Statistics*, 52(6), pp.413-429.

- [74] Taj, S., Rizwan, S. M. and Taneja, G. (2018). Reliability analysis of a wire drawing system with mandatory rest period. *International Journal of Mechanical Engineering and Technology*, 9(4), pp.1–10.
- [75] Taj, S., Rizwan, S. M. (2019). Reliability modeling and analysis of complex industrial systems – a review, *i-manager's Journal of Mathematics*, 8 (2), pp. 43-60.
- [76] Taj, S., Rizwan, S. M., Alkali, B., Harrison, D. and Taneja, G. (2020). Three Reliability Models of a Building Cable Manufacturing Plant: A comparative Analysis. *International Journal of System Assurance Engineering and Management*, 11, pp. 239–246.
- [77] Rizwan, S. M., and Taj, S.Z., (2021). Modeling and analysis of port PLCs, *Advances in Dynamical Systems and Applications*, 16 (2), pp. 423-440