

An Analysis of Small Scale Grid Connected Rooftop Solar Power Generation-A Pilot Scheme

Jayanna Kanchikere

*Electrical & Electronics Engineering,
Bharat Institute of Engineering and Technology, Hyderabad, INDIA*

K. Kalyankumar

*Former Vice-Chancellor,
Vinayaka Mission Sikkim University, East Sikkim, India*

Abstract

Energy demand in India and especially in Karnataka state is continuously increasing, however the electric utilities failed to meet this load demand. Photovoltaic (PV) solar power plant is used for larger development of solar power generation. In a solar roof top system, the solar panels are installed on the roof of any residential, commercial, institution and industrial building. The solar roof top system may come up with storage facility using battery or grid connected. In grid connected roof top solar PV system, available roof top area on the buildings is used for setting up solar power plant and the DC power generated from solar photovoltaic panel is converted to AC power using solar grid inverter and is fed to grid during day time and in night when solar power is not sufficient, loads are served by drawing power from grid. In this research paper, real time and Simulation analysis of 8KW grid connected photovoltaic solar roof top power plant at Davangere city is carried out using PV syst. The real time meter readings on both export and import side are recorded and simulation results of energy output of inverter, energy injected into the grid and energy supplied to the user are presented.

Keywords: Grid, Roof top system, solar photovoltaic panel, solar radiation, Solar grid inverter.

I. INTRODUCTION

Solar energy is a clean, pollution free renewable source of energy. Karnataka state being located between $11^{\circ} 40'$ and $18^{\circ} 27'$ North latitude and the geographical location favors the harvesting and development of solar energy. Karnataka state is having 300 sunny days with good solar radiation of 5.4 to 6.2 KWh / square-meter

/day. Davangere city comes under Karnataka state in India which is 250KM from the Bangalore, the capital city of Karnataka state. The yearly average solar radiation on horizontal surface in Avaragere village of Davangere city is 5.24 KWh/m²/day at latitude of 14.4384 °N and longitude of 75.956082 °E [8].

In Oct 2013, Karnataka Electricity Regulatory Commission (KERC) has fixed tariff of Rs 9.56 per unit (without subsidy) and Rs 7.20 per unit (with subsidy) to the roof top solar Photovoltaic (PV) plants for the energy generated exceeding the energy consumed during a billing period. The above approved tariff is applicable to solar power generator entering into power purchase agreement (PPA) after Apr 2013 and up to Mar 2018. KERC revised again fixed tariff to Rs 7.08 per unit (without subsidy) in Apr 2016. The government of Karnataka has announced solar policy 2014-21 in May 2014 for grid connected rooftop PV systems. It is proposed to achieve a minimum of 400MW's of grid connected rooftop solar power plants in Karnataka state by 2018.

Electric utilities are finding it difficult to meet rise in peak demand and as a result, most of cities and towns are facing severe electricity shortages. Most of commercial establishments use one or more diesel generator for back-up power. In order to utilize the existing roof space of buildings, the scheme proposes to promote rooftop solar PV systems on buildings to replace diesel generator sets.

II. GRID CONNECTED ROOF TOP SOLAR POWER PLANTS

Solar PV cells converts sunlight to generate electricity through a photovoltaic process. There are two types of solar PV systems: standalone and grid connected. Standalone solar PV systems work with batteries [6]. The solar energy is stored in the battery and used to feed building loads after conversion from DC to AC power with a standalone inverter. These systems used in remote areas without grid supply. The disadvantage of these systems is that the batteries require replacement once in every 3-5 years.

In Grid connected rooftop solar power plant, the DC power generated from solar photovoltaic (SPV) panel is converted to AC power using power conditioning unit and is fed to the grid either of 11KV lines or of 415/240V, three / single phase lines and if any shortfall of solar energy is imported from grid. A schematic sketch of a typical grid connected solar rooftop photovoltaic power plant is shown in Fig1.




Fig1. A Schematic sketch of a Typical Grid connected Solar Roof Top Photo Voltaic Power Plant.

Solar PV cells generate power during the day time which is utilized fully by powering captive loads and feed excess power to grid [3]. In case solar power is not sufficient due to cloud cover, the captive loads are served by drawing power from grid. The grid-interactive roof top system can work on net-metering basis where in utility pays to the power plant owner on net metering basis only. Two meters can also be installed to measure the export and import of power separately. Grid interactive systems do not require battery backup as utility grid acts as the backup to feed excess solar power and vice-versa [4]. To enhance the reliability of overall systems, a minimum battery backup of one hour of load capacity is recommended.

III COMPONENTS OF SOLAR PV SYSTEM

A Grid-connected solar PV system consists of following main components [1]:

A. Solar photovoltaic (PV) modules

Solar PV modules are mounted on the roof of buildings and convert sunlight into direct current. The size of a solar PV system depends on the 90% energy consumption of the building and the shade-free rooftop area available. To achieve a required voltage and current, a group of PV modules are wired into large array called PV array.

B. Solar PV array support structure

These are galvanized steel structures secure the solar PV modules on the roof of building. The mounting structures require roof to be penetrated and mounting solar panels correctly is part of maximizing power generation.

C. Solar grid inverter

Solar grid inverter converts generated direct current into alternating current which is required for all electrical appliances through a charge controller. It also regulates battery charging if required.

D. Balance of system

All other components considered for solar rooftop power plant are cables, junction boxes, fuses etc.

The size of solar plant require depends on requirement of electrical load, number of KWh consumption and how much money would we like to earn etc. The size of solar plant is limited by the extent of shaded free rooftop space available. The expected life of solar PV plant is 25 years.

IV REAL TIME SYSTEM DESIGN

The main target is to design and install 8KW solar rooftop solar power plant.

A. Key facts of solar rooftop power plant

Plant capacity in KWp : 8KWp Rooftop Solar power plant

PV Technology/Module: Polycrystalline modules

Power conditioning unit: 8 KVA

Power evacuation : 415/240V, three/single-phase, 50HZ

A typical Design of 8KW Solar Roof Top Power Plant of Avaragere village in Davangere city is shown in Fig 2.




Fig 2 A typical Design of 8 KW Roof Top Solar Power Plant at Avaragere, Davangere City.

Actual on-site 8KW Solar Roof Top Power Plant of Avaragere village in Davangere city is shown in Fig 3.



Fig 3. Actual onsite of 8KW solar roof top plant at Avaragere, Davangere city

B. System capacity based on rooftop area

Total Power output = Total area \times Solar irradiance \times Conversion efficiency

$$8000 = \text{Total area} \times 1000 \text{ Watts/m}^2 \times 0.1537$$

Total area required for 8KWp = 52 Sq.m = 560sq.feet

The rooftop area required to install 8KWp is around 600 sq.feet.

C. Number of PV panels for the system

Divide the total watt-hours per day needed from PV panels by the rated output watt-peak of PV modules.

Capacity of each module: 250Wp

Number of PV panels or modules required = $8000\text{Wp} / 250\text{WP} = 32$

Number of strings as per system Design = 02 Numbers

Number of solar panels in each string = 16

The maximum power of this module is 250Wp; hence it requires 32 modules to design 8KW PV system. The selected PV is manufactured by Emvee Solar and onsite arrangement of solar PV modules at Avaragere, Davangere is shown in Fig 4.



Fig 4. Actual onsite of 8KW solar roof top PV modules at Avaragere, Davangere city

The PV module parameters and ratings [2] are given in Table 1 and more specifications of PV module and dimension [7] are given in Table 2.

Table 1. PV module parameters and ratings

| Electrical Characteristics | |
|-----------------------------|-----------------|
| Rated Maximum power (Pmax) | 250Wp |
| Maximum power voltage (Vmp) | 30.84 V |
| Maximum power current (Imp) | 8.15A |
| Open circuit voltage (Voc) | 37.26V |
| Short circuit current (Isc) | 8.907A |
| Module efficiency | 15.37% |
| Operating temperature | - 40°C to +85°C |

Table 2. PV module specifications and dimension

| Specifications and Dimensions of PV module | |
|--|-------------------------------|
| Solar cells | Multi crystalline solar cells |
| Solar cell size | 156 mmx156 mm(6 inx6 in) |
| Number of cells(pieces) | 60 (6x10) |
| Module dimensions | 1644 mm x994 mm x50 mm |
| Weight | 18.8 kg |
| Front glass | 3.2 mm tempered glass |
| Frame | Anodized aluminum alloy |
| Protection degree | IP 65 |
| High efficiency | 17.4% |
| Grid connection | ON/OFF grid |
| No. of PV modules/panels | 20 |

D. Solar Grid Inverter rating

The recommended solar grid inverter capacity is in the range of 95% to 110% of solar PV array capacity. The solar array PV capacity is 8KW. The solar grid inverter requires will be in range of 7.6KW to 8.8KW. For grid connected, input rating of inverter should be same as PV array rating [5]. For this system, solar grid inverter used is 8KVA of ABB make is shown in Fig 5.

The inverter parameters are given in Table 3

Table 3. Inverter parameters

| Inverter specifications | |
|---------------------------|-----------------------|
| 3-phase inverter chosen | 8KVA on grid inverter |
| Maximum efficiency | 98% |
| Maximum ac output current | 35A |
| Maximum ac output power | 8000W |
| Rated ac power | 7360W |
| Rated ac grid voltage | 415V |



Fig 5. Actual onsite 8KVA solar grid inverter at Avaragere, Davangere city

E. Distribution Transformer rating

The details of distribution transformer used in this analysis are Summarized as follows:

Location of Distributing Transformer: Kudli Ranga Rao DTC, Davangere city

Capacity of Distribution Transformer: 100KVA

Total connected load in KW: 53 KW

Tong Tester reading at current in all 3-phases and

Neutral: 62A, 60A, 60A

The rating of SRTPV capacity = 8KWp

Total generating capacity in KWp = 8KWp

F. Feeder rating

The details of feeder are summarized as follows:

Name of 11KV Feeder: Avaragere, Davangere city.

Feeder Number: F-7

Name of 66 / 11 KV substation: Avaragere, Davangere city

Type of conductor / cable (Size): Rabbit

Total connected load on feeder in KVA: 2731KVA

Total capacity (KWp) of SRTPV system: 800KWp connected on feeder.

Peak load on feeder in Amperes: 60 Amps

G. Meter specifications

The meter specifications are given below:

Meter Number (RR Number) : AVAEH 27317

Tariff: LT – 2(A)

Phase: 1- phase LT or 3-Phase LT/HT: BS RTPV-13 /31.12.15

Sanctioned Load: 1 KW

Make: Secure sprint 350, 3-phase, 10-60A (Bidirectional)

L and G, 3-phase, 5-30A, solar grid side

V. REAL TIME TEST RESULTS

A. Meter output readings on Import and Export side

The output meter readings of energy meters on import side and export side at the time of installation are tabulated in Table 4.

Table 4 Meter reading on Import and Export side at the time of installation.

| Import side | | | |
|--------------------|---------------|---------------|----------|
| C KWh | C KVArh (lag) | C KVArh(lead) | C KVAh |
| 0.899908 | 0.328637 | 0.178941 | 1.087422 |
| Export side | | | |
| C KWh | C KVArh (lag) | C KVArh(lead) | C KVAh |
| 0.703373 | 0.277700 | 0.210893 | 0.863453 |

The output meter readings of energy meters on import side and export side after 15 days of installation on 21.05.2016 are tabulated in Table 5.

Table 5 Meter reading on Import and Export side after 15 days of installation on 21.05.2016.

| Import side | | | |
|-------------|---------------|---------------|--------|
| C KWh | C KVARh (lag) | C KVARh(lead) | C KVAh |
| 390 | 6.07 | 5.3 | 391.7 |
| Export side | | | |
| C KWh | C KVARh (lag) | C KVARh(lead) | C KVAh |
| 387 | 3.8 | 3.0 | 389 |

The Energy generated from the actual site of 8KW solar roof top plant at Avaragere, Davangere on 21.05.2016 is 38.6 Kwh.

A perfectly efficient 8KW Solar system would generate about (4.8 peak sun hours x 8KW=) 38.4 KWh of power per day.

Table 6 shows the residential solar PV index of pricing, electricity yield and returns of 8KWp Solar PV systems.

Table 6 The residential solar PV index [9].

| Solar Choice Residential Solar System Payback Estimator | | | | | | | | | | |
|---|----------------------------|----------------------------|--------------------------------------|---------------------------------------|-------------------------------------|-------------------------------------|---|--|--|--------|
| Solar | | | | | | | | Electricity usage | | |
| Inputs (Enter values only in cells with white backgrounds) | System size (kW) | Average daily sun hours* | Solar system out-of-pocket cost | Feed-in tariff rate (\$/kWh) | Cost of retail electricity (\$/kWh) | Self consumption ratio ^x | Solar system efficiency factor ^t | Average daily household energy usage (kWh) | Quarterly household energy usage (kWh, based on daily usage) | |
| | | 8 | 6.2 | \$12,280 | \$0.08 | \$0.25 | 0.6 | 0.7 | 30 | 2737.5 |
| Outputs | Solar power produced (kWh) | Solar power consumed (kWh) | Solar power exported to grid (kWh) | Total power purchased from grid (kWh) | Value of solar power consumed | Value of solar exported to grid | Total savings from solar | Total electricity usage charges with solar | Total electricity usage charges without solar | |
| | Daily [^] | 34.7 | 20.8 | 13.9 | 9.2 | \$5.21 | \$1.11 | \$6.32 | \$1.18 | \$7.50 |
| | Quarterly [^] | 3168.2 | 1900.9 | 1267.3 | 836.6 | \$475.23 | \$101.38 | \$632.00 | \$108 | \$750 |
| | Additional inputs | | | | | | | | | |
| | Number of years to pay off | | Annual internal rate of return (IRR) | | Annual savings (Year 1) | | System net present value (NPV) ^ø | | Assumed electricity inflation rate (%) | 2.50% |
| | 5.19 | | 20% | | \$2,288 | | \$24,249 | | Assumed discount rate (%) | 5.00% |
| | | | | | | | | | Assumed FIT annual increase rate (%) | 1.20% |

VI. SIMULATION ANALYSIS RESULTS

The global system configuration of the PV array is shown in Fig.6

Global System configuration

1 Number of kinds of sub-arrays

Simplified Schema

Global system summary

| | | | |
|------------------|-------------------|------------------|----------|
| Nb. of modules | 32 | Nominal PV Power | 8.0 kWp |
| Module area | 53 m ² | Maximum PV Power | 7.9 kWdc |
| Nb. of inverters | 1 | Nominal AC Power | 8.0 kWac |

PV Array

Sub-array name and Orientation

Name: PV Array

Orient: Fixed Tilted Plane

Tilt: 30°
Azimuth: 0°

Presizing Help

No sizing

Enter planned power: 8.0 kWp

... or available area(modules): 53 m²

Select the PV module

Prod. from 2011 Approx. needed modules: 32

Emmvee Solar 250 Wp 25V Si-mono Emmvee Diamond 250 Since 2011 Manufacturer 2C

Sizing voltages: Vmpp (60°C) 25.4 V
Voc (-10°C) 41.4 V

Use Optimizer

Select the inverter

Prod. from 2011 50 Hz
 60 Hz

ABB 8.0 kW 335 - 800 V TL 50/60 Hz PVS300-TL-8000W-2 Since 2011

Nb. of inverters: 1 Operating Voltage: 335-800 V Global Inverter's power: 8.0 kWac
Input maximum voltage: 900 V **"String" inverter with 4 inputs**

Design the array

Number of modules and strings

Mod. in series: 16 between 14 and 21

Nbre strings: 2 only possibility 2

Overload loss: 0.0 %

Pnom ratio: 1.00

Nb. modules: 32 Area: 53 m²

Operating conditions

Vmpp (60°C) 407 V
Vmpp (20°C) 494 V
Voc (-10°C) 662 V

Plane irradiance: 1000 W/m²

I_{mp} (STC) 16.6 A
I_{sc} (STC) 17.8 A
I_{sc} (at STC) 17.5 A

Max. in data STC

Max. operating power: 7.1 kW
at 1000 W/m² and 50°C

Array nom. Power (STC): 8.0 kWp

Fig.6 The global system configuration of the PV array

The main Simulation results of 8KW simulation project are presented in Table7

Table 7. Main Simulation results

New simulation variant
Energy use and User's needs

| | E Avail | E Load | E User | E_Grid | SolFrac |
|------------------|----------------|---------------|---------------|---------------|----------------|
| | kWh | kWh | kWh | kWh | |
| January | 1382 | 79.15 | 37.73 | 1344 | 0.477 |
| February | 1246 | 71.49 | 37.72 | 1208 | 0.528 |
| March | 1342 | 72.64 | 39.39 | 1302 | 0.542 |
| April | 1125 | 70.30 | 37.99 | 1087 | 0.540 |
| May | 1019 | 72.64 | 39.36 | 979 | 0.542 |
| June | 810 | 60.25 | 33.99 | 776 | 0.564 |
| July | 770 | 62.25 | 35.32 | 735 | 0.567 |
| August | 822 | 62.25 | 35.11 | 787 | 0.564 |
| September | 970 | 70.30 | 37.75 | 932 | 0.537 |
| October | 1182 | 72.64 | 38.38 | 1143 | 0.528 |
| November | 1234 | 70.30 | 36.80 | 1197 | 0.524 |
| December | 1370 | 79.15 | 37.51 | 1333 | 0.474 |
| Year | 13272 | 843.35 | 447.05 | 12825 | 0.530 |

The available energy at inverter output/day is shown in Fig.7




Fig7. The available energy at inverter output /day

The energy injected into grid is shown in Fig.8




Fig.8 Energy injected into grid

The energy supplied to the user is shown in Fig.9




Fig.9 Energy supplied to the user

VII. CONCLUSIONS

The real time design of an 8KW solar PV power plant located on the roof of a residential building in Davangere city is carried out by means of determining the engineering standards and realistic constraints of design. The required shaded free roof top area for installing such plant is found to 600 sft. We study how to establish a real time design of 8KW photovoltaic solar roof top power plant and installation of the 8KW roof top plant and the meter output reading on both import and export side are recorded and it is observed that the available energy at inverter output is 38.6 KWh/day. The available energy at the inverter output is indicated by import side meter and the energy injected into the grid is indicated by meter on export side. The energy supplied to user is the difference of these two meters after meeting losses. The Simulation analysis of 8KW solar PV power plant located on the roof of a residential building in Davangere city is also carried out by the software PV syst. From the simulation results, the horizontal global irradiation is 5.708 Kwh/m².day and the available energy at inverter output is 44.59KWh/day. The energy injected into grid is 43.37 KWh/day. The energy supplied to the user is 1.217KWh/day. The duration of PV production of the considered array is 10.52Hour. These outputs reading vary with respect to irradiation. The opportunity to build and design large scale PV roof top Power plants is a future growth.

ACKNOWLEDGMENT

The authors wish to acknowledge the support from Mr. Abhishek of Bunt solar India Private Limited, Mr. Ravi R Kamath and Family of Davangere city and BESCO, Davangere city

REFERENCES

- [1] Jayanna Kanchikere and K KalyanKumar, "Estimation of cost analysis for 5KW grid connected solar roof top power plant: A case study", International Journal of engineering science and computing, vol 6, Issue 4, PP. 4505-4507, Apr 2016.
- [2] Jayanna Kanchikere, kotresh K and K KalyanKumar, "A 5KW photovoltaic solar roof top power plant design : An analysis", International Journal of engineering science and computing, vol 6, Issue 4, PP. 4501-4504, Apr 2016.
- [3] Vinay Janardhan shetty and Keerti Kulkarni, "Estimation of cost analysis for 500KW grid connected solar photovoltaic plan: A case study", International Journal of current engineering and technology, vol 4, PP. 1859-1861, No.3, June 2014.
- [4] Pradeep Paleli and Harini challapally, "Roof top solar and netmetering in India- A Detailed Analysis", PP.1-6, Efficientcarbon.com

- [5] Hemakshi Bhoje, Gaurang and Sharma, “ An analysis of one MW photovoltaic solar power plant design”, International Journal of Advanced research in Electrical, Electronics and Instrumentation Engineering, vol 3, Issue 1, PP 6969-6973,Jan2014.
- [6] Radhey S M, Jeetendra Singh Rathore and Shivani J, “Grid connected roof top solar power generation: A review”, International Journal of Engineering development and research, vol 3, Issue 1,PP.325-330,2014.
- [7] M.H.Albadi,RS Alabri,MI masoud,KH Alsaidi,A Al Lawati,Al Ajmi, I Al Farsi,”Design of 50KW solar PV roof top system”, International Journal of Smart Grid and Clean Energy,vol 3,No.4,PP.41-409,2014
- [8] <https://eosweb.larc.nasa.gov/sse>.
- [9] www.solarchoice.net.au